

EVACUATION OPTION	POWERED WHEELCHAIR USER	WHEELCHAIR USER	OTHER MOBILITY IMPAIRED PERSON	BREATHING/OTHER HEALTH ISSUES	VISUALLY IMPAIRED PERSON	HEARING IMPAIRED PERSON	COGNITIVE DISABILITY/ DISLEXIC, ORIENTATION DISORDERS	LEARNING DISABILITY	MENTAL HEALTH DISABILITY	DEXTERITY DISABILITY
1	●	●	●	●						●
2		●	●		●				●	
3	●	●	●	●	●	●	●	●	●	●
4	●	●	●	●	●					
5	●	●	●	●				●		
6	●	●	●	●						
7	●	●	●	●						
8	●	●	●	●						
9	●	●	●	●						
10		●								
11	●	●								
12	●	●	●	●	●			●		
13	●	●	●	●	●			●	●	●
14	●	●	●	●	●			●		
15					●	●	●	●	●	
16					●					
17					●		●	●	●	
18			●		●	●	●	●	●	
19				●	●	●	●	●		
20				●	●					
21										●
22					●		●	●		
23					●	●	●	●	●	
24						●				
25					●	●	●			
26	●	●	●			●				
27	●	●	●		●	●				
28						●	●	●	●	
29	●	●								
30					●		●	●	●	

NOTE: The above options should be used as a guidance only.

EVACUATION OPTIONS

- Option 1. Use of a lift
- Option 2. Meet assistance at temporary waiting space
- Option 3. Meet assistance at work location
- Option 4. Make own way down stairs slowly
- Option 5. Use some other way of moving down stairs, i.e. not walking after main flow
- Option 6. Use an evacuation chair or similar
- Option 7. Carry down – 2 persons
- Option 8. Carry down – 3 persons
- Option 9. Carry down – 4 persons
- Option 10. Travel down in own chair with support
- Option 11. Cannot transfer readily from wheelchair
- Option 12. Travel down stairs using handrails
- Option 13. Assistance from 1 person
- Option 14. Assistance from 2 people
- Option 15. Orientation information
- Option 16. Tactile map of the building
- Option 17. Colour coding or contrasting on escape routes
- Option 18. Step edge markings
- Option 19. Needs to be shown the escape routes
- Option 20. Needs assistance for the person and their dog
- Option 21. Needs doors to be opened
- Option 22. Large print information
- Option 23. Identification of escape routes by reception or security staff
- Option 24. Flashing beacons
- Option 25. Buddy system
- Option 26. Vibrating pagers
- Option 27. Alternative communication system
- Option 28. Additional checks by fire wardens
- Option 29. Horizontal evacuation into another fire compartment
- Option 30. Taped information